

CONTROL KIOSK (REFER TO DCWW STANDARD DETAILS)

CONCRETE SLAB TO TOP OF CHAMBERS  
(REFER TO DCWW STANDARD DETAILS)

CLEAN STONE 14 TO 20mm WITHIN FENCE/BOLLARD  
BOUNDARY (PERMEABLE AREA)

TREATED EDGE BOARDING  
AROUND BOUNDARY TO STONE

CONCRETE TOP SLAB

BOUNDARY FENCING IF REQUIRED,  
TO DCWW SECURITY STANDARD

GATES TO OPEN INWARDS  
& BE COMPLIANT WITH DCWW  
SECURITY SPECIFICATION

DROP DOWN LOCKABLE  
BOLLARDS

DROP DOWN LOCKABLE  
BOLLARDS

4000 GALLON TANKER  
(APPROX 12.25m x 2.45m)

INLET MH

WET WELL

VALVE  
CHAMBER

TANKER DRAIN

REINFORCED CONCRETE  
LAYBY/TANKER PARKING


RAISED KERB LINE

PERMEABLE HARDSTANDING

BOLLARDS

### PLAN OF TYPICAL LAYOUT

(SHOWING MINIMUM DIMENSIONS,  
ORIENTATION TO SUIT SITE SPECIFIC LAYOUT)



#### NOTES

1. THIS DRAWING TO BE READ IN CONJUNCTION WITH CS501 (CESWI 7th EDITION) AND CS501A (DCWW CIVIL SPECIFICATION).
2. FINISHED GROUND LEVEL TO BE AGREED AND CONFIRMED WITH LAND OWNER & DCWW LAND AGENT.
3. EXACT ORIENTATION OF STRUCTURES AND COMPOUND TO BE DETERMINED BY SITE CONDITIONS.
4. A HAMMER HEAD TANKER TURNING AREA MAY BE REQUIRED FOR MAJOR ROADS.

A	FIRST ISSUE	TD	PM		JULY 2013
REV	REVISION	DRN	CHK	REVD	DATE



## DCWW STANDARD DRAWINGS

GROUP:SD19

### PACKAGE PUMPING STATIONS

#### TITLE: TYPICAL TYPE 3 PUMPING STATION LAYOUT

	INITIALS	DATE	SCALES
DRAWN BY:	TD	SEPT. 2012	1:50
CHECKED BY:	PM	JULY 2013	
REVIEWED BY:	RD	JULY 2013	

DIMENSIONS IN MILLIMETRES A3

CLIENT DRAWING NO. REV.  
SDM4001/005 A